



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

January 07, 2021

Patrick Pomerville
Waterford Halfmoon School Dist.
125 Middletown Road
Waterford, NY 12188

Work Order No: 201211015

TEL: (518) 237-0800

RE: Water Analysis
WHUFSD High School

Dear Patrick Pomerville:

Adirondack Environmental Services, Inc received 58 samples on 12/11/2020 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

A handwritten signature in black ink, appearing to read "Chris Hess".

Christopher Hess
QA Manager

ELAP#: 10709

Waterford Halfmoon School Dist.

Date: 07-Jan-21

Water Analysis

Lab WorkOrder: 201211015

WHUFSD High School

The sampling was performed in accordance with the AES field sampling procedures and/or the client specified sampling procedures. Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers: ND : Not Detected at reporting limit	C: CCV below acceptable Limits
J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
H: Hold time exceeded	Z: Duplication outside acceptable limits
N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 07-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD High School

LabWork Order: 201211015
PO#:

Lab SampleID: 201211015-001**Collection Date:** 12/11/2020**Client Sample ID:** HS-01**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 6:33:13 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-002**Collection Date:** 12/11/2020**Client Sample ID:** HS-02**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 6:44:25 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-003**Collection Date:** 12/11/2020**Client Sample ID:** HS-03**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 6:48:10 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-004**Collection Date:** 12/11/2020**Client Sample ID:** HS-04**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 6:51:55 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-005**Collection Date:** 12/11/2020**Client Sample ID:** HS-05**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 7:03:07 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 07-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD High School

LabWork Order: 201211015
PO#:

Lab SampleID: 201211015-006 **Collection Date:** 12/11/2020
Client Sample ID: HS-06 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 7:06:53 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-007 **Collection Date:** 12/11/2020
Client Sample ID: HS-07 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 7:10:39 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-008 **Collection Date:** 12/11/2020
Client Sample ID: HS-08 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 7:14:21 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-009 **Collection Date:** 12/11/2020
Client Sample ID: HS-09 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 7:18:03 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-010 **Collection Date:** 12/11/2020
Client Sample ID: HS-10 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	1.2	1.0		µg/L	1	1/6/2021 7:21:45 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 07-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD High School

LabWork Order: 201211015
PO#:

Lab SampleID: 201211015-011 **Collection Date:** 12/11/2020
Client Sample ID: HS-11 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	1.9	1.0		µg/L	1	1/6/2021 7:25:28 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201211015-012 **Collection Date:** 12/11/2020
Client Sample ID: HS-12 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	1.0	1.0		µg/L	1	1/6/2021 7:36:38 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201211015-013 **Collection Date:** 12/11/2020
Client Sample ID: HS-13 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	2.7	1.0		µg/L	1	1/6/2021 7:47:48 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201211015-014 **Collection Date:** 12/11/2020
Client Sample ID: HS-14 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	1.2	1.0		µg/L	1	1/6/2021 7:51:33 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201211015-015 **Collection Date:** 12/11/2020
Client Sample ID: HS-15 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 7:55:17 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 07-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD High School

LabWork Order: 201211015
PO#:

Lab SampleID: 201211015-016 **Collection Date:** 12/11/2020
Client Sample ID: HS-16 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 7:59:02 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-017 **Collection Date:** 12/11/2020
Client Sample ID: HS-17 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 8:02:47 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-018 **Collection Date:** 12/11/2020
Client Sample ID: HS-18 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 8:06:29 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-019 **Collection Date:** 12/11/2020
Client Sample ID: HS-19 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 8:10:11 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-020 **Collection Date:** 12/11/2020
Client Sample ID: HS-20 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 8:13:54 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 07-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD High School

LabWork Order: 201211015
PO#:

Lab SampleID: 201211015-021 **Collection Date:** 12/11/2020
Client Sample ID: HS-21 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 8:32:29 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-022 **Collection Date:** 12/11/2020
Client Sample ID: HS-22 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 8:43:40 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-023 **Collection Date:** 12/11/2020
Client Sample ID: HS-23 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 8:47:25 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-024 **Collection Date:** 12/11/2020
Client Sample ID: HS-24 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	1.9	1.0		µg/L	1	1/6/2021 8:51:09 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201211015-025 **Collection Date:** 12/11/2020
Client Sample ID: HS-25 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	3.1	1.0		µg/L	1	1/6/2021 8:54:54 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 07-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD High School

LabWork Order: 201211015
PO#:

Lab SampleID: 201211015-026 **Collection Date:** 12/11/2020
Client Sample ID: HS-26 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 8:58:37 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-027 **Collection Date:** 12/11/2020
Client Sample ID: HS-27 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 9:02:19 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-028 **Collection Date:** 12/11/2020
Client Sample ID: HS-28 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 9:13:28 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-029 **Collection Date:** 12/11/2020
Client Sample ID: HS-29 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 9:17:11 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-030 **Collection Date:** 12/11/2020
Client Sample ID: HS-30 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 9:20:54 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 07-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD High School

LabWork Order: 201211015
PO#:

Lab SampleID: 201211015-031 **Collection Date:** 12/11/2020
Client Sample ID: HS-31 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 9:24:37 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-032 **Collection Date:** 12/11/2020
Client Sample ID: HS-32 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 9:35:48 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-033 **Collection Date:** 12/11/2020
Client Sample ID: HS-33 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 9:39:33 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-034 **Collection Date:** 12/11/2020
Client Sample ID: HS-34 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 9:43:17 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-035 **Collection Date:** 12/11/2020
Client Sample ID: HS-35 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 9:47:02 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 07-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD High School

LabWork Order: 201211015
PO#:

Lab SampleID: 201211015-036 **Collection Date:** 12/11/2020
Client Sample ID: HS-36 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 9:58:12 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201211015-037 **Collection Date:** 12/11/2020
Client Sample ID: HS-37 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	1.1	1.0		µg/L	1	1/6/2021 10:01:55 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 201211015-038 **Collection Date:** 12/11/2020
Client Sample ID: HS-38 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	2.9	1.0		µg/L	1	1/6/2021 10:05:37 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 201211015-039 **Collection Date:** 12/11/2020
Client Sample ID: HS-39 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	2.5	1.0		µg/L	1	1/6/2021 10:09:20 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 201211015-040 **Collection Date:** 12/11/2020
Client Sample ID: HS-40 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	3.4	1.0		µg/L	1	1/6/2021 10:13:03 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 07-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD High School

LabWork Order: 201211015
PO#:

Lab SampleID: 201211015-041 **Collection Date:** 12/11/2020
Client Sample ID: HS-41 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 10:24:14 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 201211015-042 **Collection Date:** 12/11/2020
Client Sample ID: HS-42 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	1.0	1.0		µg/L	1	1/6/2021 10:42:54 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 201211015-043 **Collection Date:** 12/11/2020
Client Sample ID: HS-43 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	2.5	1.0		µg/L	1	1/6/2021 10:46:39 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 201211015-044 **Collection Date:** 12/11/2020
Client Sample ID: HS-44 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 10:50:22 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 201211015-045 **Collection Date:** 12/11/2020
Client Sample ID: HS-45 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	8.7	1.0		µg/L	1	1/6/2021 10:54:06 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 07-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD High School

LabWork Order: 201211015
PO#:

Lab SampleID: 201211015-046 **Collection Date:** 12/11/2020
Client Sample ID: HS-46 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	24.9	1.0	X	µg/L	1	1/6/2021 10:57:49 PM
------	------	-----	---	------	---	----------------------

Lab SampleID: 201211015-047 **Collection Date:** 12/11/2020
Client Sample ID: HS-47 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 11:01:32 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 201211015-048 **Collection Date:** 12/11/2020
Client Sample ID: HS-48 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 11:05:16 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 201211015-049 **Collection Date:** 12/11/2020
Client Sample ID: HS-49 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	ND	1.0		µg/L	1	1/6/2021 11:08:59 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 201211015-050 **Collection Date:** 12/11/2020
Client Sample ID: HS-50 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)

Lead	6.6	1.0		µg/L	1	1/6/2021 11:12:43 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 07-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD High School

LabWork Order: 201211015
PO#:

Lab SampleID: 201211015-051 **Collection Date:** 12/11/2020
Client Sample ID: HS-51 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)
 Lead **ND** 1.0 µg/L 1 1/6/2021 11:16:27 PM

Lab SampleID: 201211015-052 **Collection Date:** 12/11/2020
Client Sample ID: HS-52 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)
 Lead **ND** 1.0 µg/L 1 1/6/2021 11:35:07 PM

Lab SampleID: 201211015-053 **Collection Date:** 12/11/2020
Client Sample ID: HS-53 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)
 Lead **ND** 1.0 µg/L 1 1/6/2021 11:38:52 PM

Lab SampleID: 201211015-054 **Collection Date:** 12/11/2020
Client Sample ID: HS-54 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)
 Lead **ND** 1.0 µg/L 1 1/6/2021 11:42:35 PM

Lab SampleID: 201211015-055 **Collection Date:** 12/11/2020
Client Sample ID: HS-55 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/11/2020)
 Lead **ND** 1.0 µg/L 1 1/6/2021 11:46:19 PM

Adirondack Environmental Services, Inc

Date: 07-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
WHUFSD High School

LabWork Order: 201211015
PO#:

Lab SampleID: 201211015-056 **Collection Date:** 12/11/2020
Client Sample ID: HS-56 **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(**Prep:** - 12/11/2020)
Lead **ND** 1.0 µg/L 1 1/6/2021 11:50:03 PM

Lab SampleID: 201211015-057 **Collection Date:** 12/11/2020
Client Sample ID: HS-57 **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(**Prep:** - 12/11/2020)
Lead **ND** 1.0 µg/L 1 1/6/2021 11:53:46 PM

Lab SampleID: 201211015-058 **Collection Date:** 12/11/2020
Client Sample ID: HS-58 **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(**Prep:** - 12/11/2020)
Lead **ND** 1.0 µg/L 1 1/6/2021 11:57:30 PM



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 201211015

COC Reference: 1378

A full service analytical research laboratory offering solutions to environmental concerns

Waterford-Halfmoon CSD		Address:	
Send Report to:		Project Name (Location): WHUFSD High School	
Client Phone #:		Client PO #:	
Client Email:		Samplers Name: <i>Charles Hatcher / Patrick O'Neil</i>	
		Samplers Signature: <i>Patrick O'Neil</i>	

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
001	HS-01	12/11/20	5:27	PW		X	1	0	Lead
002	HS-02		5:27	PW		X	1	0	Lead
003	HS-03		5:27	PW		X	1	0	Lead
004	HS-04		5:34	PW		X	1	0	Lead
005	HS-05		5:33	PW		X	1	0	Lead
006	HS-06			PW		X	1	0	Lead
007	HS-07			PW		X	1	0	Lead
008	HS-08			PW		X	1	0	Lead
009	HS-09			PW		X	1	0	Lead
010	HS-10			PW		X	1	0	Lead
011	HS-11		5:35	PW		X	1	0	Lead
012	HS-12		5:37	PW		X	1	0	Lead
013	HS-13		5:37	PW		X	1	0	Lead
014	HS-14		5:37	PW		X	1	0	Lead
015	HS-15		5:40	PW		X	1	0	Lead
016	HS-16		5:40	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:	Special Instructions/Remarks: PLEASE FILL ALL PINK SHADED AREAS
Turnaround Time Requested: <input checked="" type="checkbox"/> 1 Day <input type="checkbox"/> 2 Day <input type="checkbox"/> 3 Day <input type="checkbox"/> 5 Day <input type="checkbox"/> Standard NOTE: Samples received after 3:30pm are considered next business day.	

Relinquished by: (Signature) <i>Patrick O'Neil</i>	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by: <i>A. Carter</i>	Date 12/11/20	Time 9:05am

Sample Temperature Ambient <u>19°C</u> Notes: Ice preservation not required	Properly Preserved: <u>Y</u> / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/Na 4=Na ₂ S ₂ O ₃ 9=NaOH pl 10=Other_	Received Within Holding Times: <u>Y</u> / N
Bottles AES: <u>Y</u> / N		





314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 201211015

COC Reference:
1378

A full service analytical research laboratory offering solutions to environmental concerns

Waterford-Halfmoon CSD		Address:	
Send Report to:		Project Name (Location): WHUFSD High School	
Client Phone #:		Client PO #:	
Client Email:		Samplers Name: <i>Charles Halpern / Patrick Okoniar</i>	
		Samplers Signature: <i>CHH / POK</i>	

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
017	HS-17	12/11/20	540	PW		X	1	0	Lead
018	HS-18		540	PW		X	1	0	Lead
019	HS-19		540	PW		X	1	0	Lead
020	HS-20		543	PW		X	1	0	Lead
021	HS-21		543	PW		X	1	0	Lead
022	HS-22		543	PW		X	1	0	Lead
023	HS-23		545	PW		X	1	0	Lead
024	HS-24		546	PW		X	1	0	Lead
025	HS-25		550	PW		X	1	0	Lead
026	HS-26		552	PW		X	1	0	Lead
027	HS-27		↓	PW		X	1	0	Lead
028	HS-28		↓	PW		X	1	0	Lead
029	HS-29		↓	PW		X	1	0	Lead
030	HS-30		554	PW		X	1	0	Lead
031	HS-31		554	PW		X	1	0	Lead
032	HS-32		556	PW		X	1	0	Lead

Shipment Arrived Via:
 FedEx UPS Client AES Other:

Turnaround Time Requested:
 1 Day 2 Day 3 Day 5 Day Standard
 NOTE: Samples received after 3:30pm are considered next business day.

Special Instructions/Remarks:
 PLEASE FILL ALL PINK SHADED AREAS

Relinquished by: (Signature) <i>CHH</i>	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by: <i>ACD</i>	Date 12/11/20	Time 9:05am

Sample Temperature Ambient Notes: Ice preservation not required Bottles AES: <u>(Y)</u> / N	Properly Preserved: (Y) / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: (Y) / N Notes:
---	---	---



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 201211015

COC Reference: 1378

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Waterford-Halfmoon CSD		Address:	
Send Report to:		Project Name (Location): WHUFSD High School	
Client Phone #:		Client PO #:	
Client Email:		Samplers Name: <i>Charles [unclear] Patrick [unclear]</i>	
		Samplers Signature: <i>[Signature]</i>	

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
033	HS-33	12/11/20	558	PW	X		1	0	Lead
034	HS-34		558	PW	X		1	0	Lead
035	HS-35		600	PW	X		1	0	Lead
036	HS-36		601	PW	X		1	0	Lead
037	HS-37		608	PW	X		1	0	Lead
038	HS-38		608	PW	X		1	0	Lead
039	HS-39		608	PW	X		1	0	Lead
040	HS-40		610	PW	X		1	0	Lead
041	HS-41		610	PW	X		1	0	Lead
042	HS-42		610	PW	X		1	0	Lead
043	HS-43		614	PW	X		1	0	Lead
044	HS-44		614	PW	X		1	0	Lead
045	HS-45		614	PW	X		1	0	Lead
046	HS-46		614	PW	X		1	0	Lead
047	HS-47		620	PW	X		1	0	Lead
048	HS-48		620	PW	X		1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:	Special Instructions/Remarks: PLEASE FILL ALL PINK SHADED AREAS
Turnaround Time Requested: <input checked="" type="radio"/> 1 Day <input type="radio"/> 2 Day <input type="radio"/> 3 Day <input type="radio"/> 5 Day <input type="radio"/> Standard NOTE: Samples received after 3:30pm are considered next business day.	

Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by: <i>[Signature]</i>	Date 12/11/20	Time 9:05am

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	Received Within Holding Times: Y / N Notes:
Bottles AES: Y / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 201211015

COC Reference:
1378

A full service analytical research laboratory offering solutions to environmental concerns

Waterford-Halfmoon CSD		Address:	
Send Report to:		Project Name (Location): WHUFSD High School	Samplers Name: <i>Charles Hacker / Patrick O'Connor</i>
Client Phone #:		Client PO #:	Samplers Signature: <i>[Signature]</i>
Client Email:			

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
049	HS-49	12/11/20	619	PW		X	1	0	Lead
050	HS-50		626	PW		X	1	0	Lead
051	HS-51		628	PW		X	1	0	Lead
052	HS-52		630	PW		X	1	0	Lead
053	HS-53		630	PW		X	1	0	Lead
054	HS-54		630	PW		X	1	0	Lead
055	HS-55		631	PW		X	1	0	Lead
056	HS-56		631	PW		X	1	0	Lead
057	HS-57		631	PW		X	1	0	Lead
058	HS-58		631	PW		X	1	0	Lead
059				PW		X	1	0	Lead
060				PW		X	1	0	Lead
061				PW		X	1	0	Lead
062				PW		X	1	0	Lead
063				PW		X	1	0	Lead
064				PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:	Special Instructions/Remarks: PLEASE FILL ALL PINK SHADED AREAS
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.	

Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by: <i>[Signature]</i>	Date 12/11/20	Time 9:05am

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes:
Bottles AES: Y / N		



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.