



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

January 05, 2021

Patrick Pomerville
Waterford Halfmoon School Dist.
125 Middletown Road
Waterford, NY 12188

Work Order No: 201209054

TEL: (518) 237-0800

RE: Water Analysis
WHUFSD Elementary

Dear Patrick Pomerville:

Adirondack Environmental Services, Inc received 88 samples on 12/9/2020 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

A handwritten signature in black ink that reads "Tara Daniels". The signature is written in a cursive style with a large initial "T".

Tara Daniels
Laboratory Director

ELAP#: 10709

Waterford Halfmoon School Dist.

Date: 05-Jan-21

Water Analysis

Lab WorkOrder: 201209054

WHUFSD Elementary

The sampling was performed in accordance with the AES field sampling procedures and/or the client specified sampling procedures. Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers: ND : Not Detected at reporting limit	C: CCV below acceptable Limits
J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
H: Hold time exceeded	Z: Duplication outside acceptable limits
N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-001 **Collection Date:** 12/9/2020
Client Sample ID: ES-01 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 1:45:07 PM

Lab SampleID: 201209054-002 **Collection Date:** 12/9/2020
Client Sample ID: ES-02 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 1:56:15 PM

Lab SampleID: 201209054-003 **Collection Date:** 12/9/2020
Client Sample ID: ES-03 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 1:59:58 PM

Lab SampleID: 201209054-004 **Collection Date:** 12/9/2020
Client Sample ID: ES-04 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 2:03:42 PM

Lab SampleID: 201209054-005 **Collection Date:** 12/9/2020
Client Sample ID: ES-05 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 2:14:52 PM

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-006 **Collection Date:** 12/9/2020
Client Sample ID: ES-06 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 2:18:37 PM

Lab SampleID: 201209054-007 **Collection Date:** 12/9/2020
Client Sample ID: ES-07 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 2:22:21 PM

Lab SampleID: 201209054-008 **Collection Date:** 12/9/2020
Client Sample ID: ES-08 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 2:26:06 PM

Lab SampleID: 201209054-009 **Collection Date:** 12/9/2020
Client Sample ID: ES-09 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 2:40:24 PM

Lab SampleID: 201209054-010 **Collection Date:** 12/9/2020
Client Sample ID: ES-10 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 2:44:05 PM

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-011 **Collection Date:** 12/9/2020
Client Sample ID: ES-11 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 2:47:47 PM

Lab SampleID: 201209054-012 **Collection Date:** 12/9/2020
Client Sample ID: ES-12 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 2:58:55 PM

Lab SampleID: 201209054-013 **Collection Date:** 12/9/2020
Client Sample ID: ES-13 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 3:10:05 PM

Lab SampleID: 201209054-014 **Collection Date:** 12/9/2020
Client Sample ID: ES-14 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 3:13:49 PM

Lab SampleID: 201209054-015 **Collection Date:** 12/9/2020
Client Sample ID: ES-15 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 3:17:32 PM

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-016 **Collection Date:** 12/9/2020
Client Sample ID: ES-16 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 3:21:17 PM

Lab SampleID: 201209054-017 **Collection Date:** 12/9/2020
Client Sample ID: ES-17 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 3:25:01 PM

Lab SampleID: 201209054-018 **Collection Date:** 12/9/2020
Client Sample ID: ES-18 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 3:28:46 PM

Lab SampleID: 201209054-019 **Collection Date:** 12/9/2020
Client Sample ID: ES-19 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 3:32:31 PM

Lab SampleID: 201209054-020 **Collection Date:** 12/9/2020
Client Sample ID: ES-20 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 3:36:13 PM

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-021 **Collection Date:** 12/9/2020
Client Sample ID: ES-21 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 3:54:47 PM

Lab SampleID: 201209054-022 **Collection Date:** 12/9/2020
Client Sample ID: ES-22 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	1.1	1.0		µg/L	1	12/31/2020 4:05:57 PM

Lab SampleID: 201209054-023 **Collection Date:** 12/9/2020
Client Sample ID: ES-23 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 4:09:41 PM

Lab SampleID: 201209054-024 **Collection Date:** 12/9/2020
Client Sample ID: ES-24 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	2.7	1.0		µg/L	1	12/31/2020 4:13:25 PM

Lab SampleID: 201209054-025 **Collection Date:** 12/9/2020
Client Sample ID: ES-25 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 4:17:09 PM

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-026 **Collection Date:** 12/9/2020
Client Sample ID: ES-26 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	1.1	1.0		µg/L	1	12/31/2020 4:20:54 PM

Lab SampleID: 201209054-027 **Collection Date:** 12/9/2020
Client Sample ID: ES-27 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 4:24:39 PM

Lab SampleID: 201209054-028 **Collection Date:** 12/9/2020
Client Sample ID: ES-28 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	7.0	1.0		µg/L	1	12/31/2020 4:35:49 PM

Lab SampleID: 201209054-029 **Collection Date:** 12/9/2020
Client Sample ID: ES-29 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 4:39:31 PM

Lab SampleID: 201209054-030 **Collection Date:** 12/9/2020
Client Sample ID: ES-30 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	1.3	1.0		µg/L	1	12/31/2020 4:43:14 PM

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-031 **Collection Date:** 12/9/2020
Client Sample ID: ES-31 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 4:46:57 PM

Lab SampleID: 201209054-032 **Collection Date:** 12/9/2020
Client Sample ID: ES-32 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	1.2	1.0		µg/L	1	12/31/2020 4:58:07 PM

Lab SampleID: 201209054-033 **Collection Date:** 12/9/2020
Client Sample ID: ES-33 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 5:01:51 PM

Lab SampleID: 201209054-034 **Collection Date:** 12/9/2020
Client Sample ID: ES-34 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	1.4	1.0		µg/L	1	12/31/2020 5:05:35 PM

Lab SampleID: 201209054-035 **Collection Date:** 12/9/2020
Client Sample ID: ES-35 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 12/9/2020)						
Lead	ND	1.0		µg/L	1	12/31/2020 5:09:20 PM

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-036 **Collection Date:** 12/9/2020
Client Sample ID: ES-36 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	2.2	1.0		µg/L	1	1/4/2021 9:19:26 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201209054-037 **Collection Date:** 12/9/2020
Client Sample ID: ES-37 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	4.6	1.0		µg/L	1	1/4/2021 9:23:11 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201209054-038 **Collection Date:** 12/9/2020
Client Sample ID: ES-38 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	1.5	1.0		µg/L	1	1/4/2021 9:26:54 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201209054-039 **Collection Date:** 12/9/2020
Client Sample ID: ES-39 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	1.4	1.0		µg/L	1	1/4/2021 9:30:37 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201209054-040 **Collection Date:** 12/9/2020
Client Sample ID: ES-40 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	1.0	1.0		µg/L	1	1/4/2021 9:34:20 AM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-041 **Collection Date:** 12/9/2020
Client Sample ID: ES-41 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	1.3	1.0		µg/L	1	1/4/2021 9:45:30 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201209054-042 **Collection Date:** 12/9/2020
Client Sample ID: ES-42 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	1.5	1.0		µg/L	1	1/4/2021 10:04:08 AM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 201209054-043 **Collection Date:** 12/9/2020
Client Sample ID: ES-43 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	1.6	1.0		µg/L	1	1/4/2021 10:07:52 AM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 201209054-044 **Collection Date:** 12/9/2020
Client Sample ID: ES-44 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	103	1.0	X	µg/L	1	1/4/2021 2:54:44 PM
------	-----	-----	---	------	---	---------------------

Lab SampleID: 201209054-045 **Collection Date:** 12/9/2020
Client Sample ID: ES-45 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 10:11:37 AM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-046 **Collection Date:** 12/9/2020
Client Sample ID: ES-46 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 10:15:22 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 201209054-047 **Collection Date:** 12/9/2020
Client Sample ID: ES-47 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	1.7	1.0		µg/L	1	1/4/2021 10:19:06 AM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 201209054-048 **Collection Date:** 12/9/2020
Client Sample ID: ES-48 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutOfService			NA		12/9/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201209054-049 **Collection Date:** 12/9/2020
Client Sample ID: ES-49 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutOfService			NA		12/9/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201209054-050 **Collection Date:** 12/9/2020
Client Sample ID: ES-50 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 10:22:49 AM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-051 **Collection Date:** 12/9/2020
Client Sample ID: ES-51 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 10:26:33 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 201209054-052 **Collection Date:** 12/9/2020
Client Sample ID: ES-52 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 11:32:58 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 201209054-053 **Collection Date:** 12/9/2020
Client Sample ID: ES-53 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 11:36:42 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 201209054-054 **Collection Date:** 12/9/2020
Client Sample ID: ES-54 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 11:40:25 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 201209054-055 **Collection Date:** 12/9/2020
Client Sample ID: ES-55 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 11:44:09 AM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-056 **Collection Date:** 12/9/2020
Client Sample ID: ES-56 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 11:47:54 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 201209054-057 **Collection Date:** 12/9/2020
Client Sample ID: ES-57 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 11:51:38 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 201209054-058 **Collection Date:** 12/9/2020
Client Sample ID: ES-58 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 11:55:23 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 201209054-059 **Collection Date:** 12/9/2020
Client Sample ID: ES-59 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	2.6	1.0		µg/L	1	1/4/2021 11:59:07 AM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 201209054-060 **Collection Date:** 12/9/2020
Client Sample ID: ES-60 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 12:10:17 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-061 **Collection Date:** 12/9/2020
Client Sample ID: ES-61 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	7.8	1.0		µg/L	1	1/4/2021 12:21:29 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 201209054-062 **Collection Date:** 12/9/2020
Client Sample ID: ES-62 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 12:32:41 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 201209054-063 **Collection Date:** 12/9/2020
Client Sample ID: ES-63 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	2.9	1.0		µg/L	1	1/4/2021 12:36:25 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 201209054-064 **Collection Date:** 12/9/2020
Client Sample ID: ES-64 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	6.5	1.0		µg/L	1	1/4/2021 12:40:09 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 201209054-065 **Collection Date:** 12/9/2020
Client Sample ID: ES-65 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	18.1	1.0	X	µg/L	1	1/4/2021 12:43:54 PM
------	------	-----	---	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-066 **Collection Date:** 12/9/2020
Client Sample ID: ES-66 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	50.5	1.0	X	µg/L	1	1/4/2021 2:58:29 PM
------	------	-----	---	------	---	---------------------

Lab SampleID: 201209054-067 **Collection Date:** 12/9/2020
Client Sample ID: ES-67 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 12:55:05 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 201209054-068 **Collection Date:** 12/9/2020
Client Sample ID: ES-68 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	5.5	1.0		µg/L	1	1/4/2021 12:58:49 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 201209054-069 **Collection Date:** 12/9/2020
Client Sample ID: ES-69 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 1:02:34 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201209054-070 **Collection Date:** 12/9/2020
Client Sample ID: ES-70 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	3.3	1.0		µg/L	1	1/4/2021 1:06:18 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-071 **Collection Date:** 12/9/2020
Client Sample ID: ES-71 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	1.9	1.0		µg/L	1	1/4/2021 1:10:02 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201209054-072 **Collection Date:** 12/9/2020
Client Sample ID: ES-72 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	3.0	1.0		µg/L	1	1/4/2021 1:21:15 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201209054-073 **Collection Date:** 12/9/2020
Client Sample ID: ES-73 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 1:24:59 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201209054-074 **Collection Date:** 12/9/2020
Client Sample ID: ES-74 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	3.0	1.0		µg/L	1	1/4/2021 1:36:09 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201209054-075 **Collection Date:** 12/9/2020
Client Sample ID: ES-75 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	1.8	1.0		µg/L	1	1/4/2021 1:39:54 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-076 **Collection Date:** 12/9/2020
Client Sample ID: ES-76 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	7.7	1.0		µg/L	1	1/4/2021 1:43:39 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201209054-077 **Collection Date:** 12/9/2020
Client Sample ID: ES-77 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	4.0	1.0		µg/L	1	1/4/2021 1:47:24 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201209054-078 **Collection Date:** 12/9/2020
Client Sample ID: ES-78 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 1:51:08 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201209054-079 **Collection Date:** 12/9/2020
Client Sample ID: ES-79 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	4.0	1.0		µg/L	1	1/4/2021 1:54:52 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201209054-080 **Collection Date:** 12/9/2020
Client Sample ID: ES-80 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	14.8	1.0		µg/L	1	1/4/2021 1:58:37 PM
------	------	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
 WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-081 **Collection Date:** 12/9/2020
Client Sample ID: ES-81 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	8.6	1.0		µg/L	1	1/4/2021 2:09:50 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201209054-082 **Collection Date:** 12/9/2020
Client Sample ID: ES-82 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	7.2	1.0		µg/L	1	1/4/2021 2:28:30 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 201209054-083 **Collection Date:** 12/9/2020
Client Sample ID: ES-83 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	17.9	1.0	X	µg/L	1	1/4/2021 2:32:15 PM
------	------	-----	---	------	---	---------------------

Lab SampleID: 201209054-084 **Collection Date:** 12/9/2020
Client Sample ID: ES-84 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 2:35:59 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 201209054-085 **Collection Date:** 12/9/2020
Client Sample ID: ES-85 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	1/4/2021 2:39:44 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 05-Jan-21

CLIENT: Waterford Halfmoon School Dist.
Project: Water Analysis
WHUFSD Elementary

LabWork Order: 201209054
PO#:

Lab SampleID: 201209054-086 **Collection Date:** 12/9/2020
Client Sample ID: ES-86 **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(**Prep:** - 12/9/2020)
Lead **ND** 1.0 µg/L 1 1/4/2021 2:43:29 PM

Lab SampleID: 201209054-087 **Collection Date:** 12/9/2020
Client Sample ID: ES-87 **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(**Prep:** - 12/9/2020)
Lead **4.0** 1.0 µg/L 1 1/4/2021 2:47:14 PM

Lab SampleID: 201209054-088 **Collection Date:** 12/9/2020
Client Sample ID: ES-88 **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(**Prep:** - 12/9/2020)
Lead **3.6** 1.0 µg/L 1 1/4/2021 2:50:59 PM



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 201209054

COC Reference: 1378

A full service analytical research laboratory offering solutions to environmental concerns

Waterford-Halfmoon CSD		Address:	
Send Report to:		Project Name (Location): WHUFSD Elementary	
Client Phone #:		Client PO #:	
Client Email:		Samplers Name: <i>Patrick O'Connor</i>	
		Samplers Signature: <i>[Signature]</i>	

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
001	001 ES-01	12/9/20	536	PW		X	1	0	Lead
002	002 ES-02		536	PW		X	1	0	Lead
003	003 ES-03		537	PW		X	1	0	Lead
004	004 ES-04		537	PW		X	1	0	Lead
005	005 ES-05		540	PW		X	1	0	Lead
006	006 ES-06		540	PW		X	1	0	Lead
007	007 ES-07		542	PW		X	1	0	Lead
008	008 ES-08		542	PW		X	1	0	Lead
009	009 ES-09		545	PW		X	1	0	Lead
010	010 ES-10		545	PW		X	1	0	Lead
011	011 ES-11		547	PW		X	1	0	Lead
012	012 ES-12		547	PW		X	1	0	Lead
013	013 ES-13		549	PW		X	1	0	Lead
014	014 ES-14		549	PW		X	1	0	Lead
015	015 ES-15		551	PW		X	1	0	Lead
016	016 ES-16		551	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other:		Special Instructions/Remarks:			
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.		PLEASE FILL ALL PINK SHADED AREAS			
Relinquished by: (Signature) <i>[Signature]</i>		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received for Laboratory by: <i>[Signature]</i>		Date 12-9-20	Time 3:30PM
Sample Temperature Ambient Notes: Ice preservation not required		Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃		Received Within Holding Times: Y / N Notes:	
Bottles AES: Y / N		5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/η 9=NaOH 10=Other			



201209054



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: **201209054**

COC Reference: **1378**

A full service analytical research laboratory offering solutions to environmental concerns

Waterford-Halfmoon CSD		Address:							
Send Report to:		Project Name (Location): WHUFSD Elementary			Samplers Name: <i>Patrick O'Connor</i>				
Client Phone #:		Client PO #:			Samplers Signature: <i>Pat O'L</i>				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
017	017 ES-17	12/9/20	553	PW		X	1	0	Lead
018	018 ES-18		553	PW		X	1	0	Lead
019	019 ES-19		555	PW		X	1	0	Lead
020	020 ES-20		555	PW		X	1	0	Lead
021	021 ES-21		556	PW		X	1	0	Lead
022	022 ES-22		556	PW		X	1	0	Lead
023	023 ES-23		558	PW		X	1	0	Lead
024	024 ES-24		558	PW		X	1	0	Lead
025	025 ES-25		559	PW		X	1	0	Lead
026	026 ES-26		559	PW		X	1	0	Lead
027	027 ES-27		602	PW		X	1	0	Lead
028	028 ES-28		602	PW		X	1	0	Lead
029	029 ES-29		609	PW		X	1	0	Lead
030	030 ES-30		609	PW		X	1	0	Lead
031	031 ES-31		608	PW		X	1	0	Lead
032	032 ES-32		608	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other: _____		Special Instructions/Remarks:				
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.		PLEASE FILL ALL PINK SHADED AREAS				
Relinquished by: (Signature) <i>Pat O'L</i>		Received by: (Signature)		Date	Time	
Relinquished by: (Signature)		Received by: (Signature)		Date	Time	
Relinquished by: (Signature)		Received for Laboratory by: <i>Carla...</i>		Date 12-9-20	Time 3:30PM	
Sample Temperature Ambient Notes: Ice preservation not required		Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FA5 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____			Received Within Holding Times: Y / N Notes:	
Bottles AES: Y / N						



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: **201209054**

COC Reference: **1378**

A full service analytical research laboratory offering solutions to environmental concerns

Waterford-Halfmoon CSD		Address:	
Send Report to:		Project Name (Location): WHUFSD Elementary	
Client Phone #:		Client PO #:	
Client Email:		Samplers Name: <i>Patrick O'Connor</i>	
		Samplers Signature: <i>PA O'L</i>	

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
033	033 ES-33	12/9/20	610	PW		X	1	0	Lead
034	034 ES-34		610	PW		X	1	0	Lead
035	035 ES-35		612	PW		X	1	0	Lead
036	036 ES-36		612	PW		X	1	0	Lead
037	037 ES-37		620	PW		X	1	0	Lead
038	038 ES-38		620	PW		X	1	0	Lead
039	039 ES-39		623	PW		X	1	0	Lead
040	040 ES-40		623	PW		X	1	0	Lead
041	041 ES-41		623	PW		X	1	0	Lead
042	042 ES-42		624	PW		X	1	0	Lead
043	043 ES-43		625	PW		X	1	0	Lead
044	044 ES-44		625	PW		X	1	0	Lead
045	045 ES-45		635	PW		X	1	0	Lead
046	046 ES-46		635	PW		X	1	0	Lead
047	047 ES-47		640	PW		X	1	0	Lead
048	048 ES-48		640	PW		X	10	0	Lead. 205

Shipment Arrived Via: FedEx UPS Client AES Other:	Special Instructions/Remarks: Turnaround Time Requested: <input checked="" type="radio"/> 1 Day <input type="radio"/> 2 Day <input type="radio"/> 3 Day <input type="radio"/> 5 Day <input type="radio"/> Standard NOTE: Samples received after 3:30pm are considered next business day.
---	--

PLEASE FILL ALL PINK SHADED AREAS			
Relinquished by: (Signature) <i>PA O'L</i>	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by: <i>an Van</i>	Date	Time
		12-9-20	3:30PM

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	Received Within Holding Times: Y / N Notes:
Bottles AES: Y / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: **201209054**

COC Reference: **1378**

A full service analytical research laboratory offering solutions to environmental concerns

Waterford-Halfmoon CSD		Address:	
Send Report to:		Project Name (Location): WHUFSD Elementary	
Client Phone #:		Samplers Name: <i>Patrick O'Connor</i>	
Client Email:		Samplers Signature: <i>[Signature]</i>	
Client PO #:			

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
049	ES-49	12/09/20	640	PW		X	16	0	Lead/005
050	ES-50		640	PW		X	1	0	Lead
051	ES-51		640	PW		X	1	0	Lead
052	ES-52		645	PW		X	1	0	Lead
053	ES-53		645	PW		X	1	0	Lead
054	ES-54		645	PW		X	1	0	Lead
055	ES-55		645	PW		X	1	0	Lead
056	ES-56		645	PW		X	1	0	Lead
057	ES-57		646	PW		X	1	0	Lead
058	ES-58		647	PW		X	1	0	Lead
059	ES-59		647	PW		X	1	0	Lead
060	ES-60		649	PW		X	1	0	Lead
061	ES-61		649	PW		X	1	0	Lead
062	ES-62		651	PW		X	1	0	Lead
063	ES-63		651	PW		X	1	0	Lead
064	ES-64		654	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other:	Special Instructions/Remarks:
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.	

PLEASE FILL ALL PINK SHADED AREAS

Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by: <i>[Signature]</i>	Date	Time
		12-9-20	3:30PM

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other_____	Received Within Holding Times: Y / N Notes:
Bottles AES: Y / N		



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: **201209054**

COC Reference: **1378**

A full service analytical research laboratory offering solutions to environmental concerns

Waterford-Halfmoon CSD		Address:	
Send Report to:		Project Name (Location): WHUFSD Elementary	
Client Phone #:		Client PO #:	
Client Email:		Samplers Name: <i>Patrick O'Connor</i>	
		Samplers Signature: <i>Pat O'</i>	

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
065	065 ES-65	12/09/20	654	PW		X	1	0	Lead
066	066 ES-66		654	PW		X	1	0	Lead
067	067 ES-67		652	PW		X	1	0	Lead
068	068 ES-68		652	PW		X	1	0	Lead
069	069 ES-69		656	PW		X	1	0	Lead
070	070 ES-70		656	PW		X	1	0	Lead
071	071 ES-71		658	PW		X	1	0	Lead
072	072 ES-72		658	PW		X	1	0	Lead
073	073 ES-73		658	PW		X	1	0	Lead
074	074 ES-74		658	PW		X	1	0	Lead
075	075 ES-75		659	PW		X	1	0	Lead
076	076 ES-76		659	PW		X	1	0	Lead
077	077 ES-77		659	PW		X	1	0	Lead
078	078 ES-78		659	PW		X	1	0	Lead
079	079 ES-79		703	PW		X	1	0	Lead
080	080 ES-80		707	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other: _____ Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.	Special Instructions/Remarks: PLEASE FILL ALL PINK SHADED AREAS
---	---

Relinquished by: (Signature) <i>Pat O'</i>	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by: <i>Pat O'</i>	Date	Time
		12-9-20	3:30 PM

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes:
Bottles AES: Y / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: **201209054**

COC Reference: **1378**

A full service analytical research laboratory offering solutions to environmental concerns

Waterford-Halfmoon CSD		Address:	
Send Report to:	Project Name (Location): WHUFSD Elementary		Samplers Name: <i>Patrick Blonzo</i>
Client Phone #:	Client PO #:		Samplers Signature: <i>PB</i>
Client Email:			

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
081	081 ES-81	12/09/20	707	PW		X	1	0	Lead
082	082 ES-82		707	PW		X	1	0	Lead
083	083 ES-83		707	PW		X	1	0	Lead
084	084 ES-84		708	PW		X	1	0	Lead
085	085 ES-85		708	PW		X	1	0	Lead
086	086 ES-86		710	PW		X	1	0	Lead
087	087 ES-87		709	PW		X	1	0	Lead
088	088 ES-88		707	PW		X	1	0	Lead
	089			PW		X	1	0	Lead
	090			PW		X	1	0	Lead
	091			PW		X	1	0	Lead
	092			PW		X	1	0	Lead
	093			PW		X	1	0	Lead
	094			PW		X	1	0	Lead
	095			PW		X	1	0	Lead
	096			PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other:	Special Instructions/Remarks:
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.	

PLEASE FILL ALL PINK SHADED AREAS

Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by: <i>[Signature]</i>	Date	Time
		12-9-20	3:30PM

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	Received Within Holding Times: Y / N Notes:
Bottles AES: Y / N		



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.